

After-Action Report

Sorority House Fire Drills

March 2, 2018

Summary

On February 27, 2018, University Safety Officer, in conjunction with Residence Life and Facilities Management, conducted fire drills in the following sorority houses on the A-State campus:

Zeta Tau Alpha, Alpha Gamma Delta, Alpha Omicron Pi, Chi Omega and Delta Zeta

The following report includes timing information and areas for improvement identified during the drills and their follow-up activities, along with steps to address the issues noted. Issues have been forwarded to the appropriate department for remedy or repair.

Zeta Tau Alpha

- Time required for total evacuation: 2:13
- Total Occupants Evacuated: 8
- Fire Code Violations: None
- Equipment Failure: None
- Procedural Observations: None

Alpha Gamma Delta

- Time required for total evacuation: 3:00
- Total Occupants Evacuated: 6
- Fire Code Violations: None
- Equipment Failure: None
- Procedural Observations: None

Alpha Omicron Pi

- Time required for total evacuation: 2:45
- Total Occupants Evacuated: 5
- Fire Code Violations: Storage that could impede egress in enclosed stairwell
 - o Action Steps: Remove combustibles (wood and plastic), find alternate storage space, remind occupants of prohibition against storage in enclosed stairwells
- Equipment Failure: None
- Procedural Observations: None

Chi Omega

- Time required for total evacuation: 1:37
- Total Occupants Evacuated: 7
- Fire Code Violations: Storage that could impede egress in enclosed stairwell
 - o Action Steps: Remove combustibles (wood and plastic), find alternate storage space, remind occupants of prohibition against storage in enclosed stairwells
- Equipment Failure: None
- Procedural Observations: Occupants gathered too close to the building
 - o Action Step: Remind occupants to move at least 100 feet away from the building in the back parking lot

Delta Zeta

- Time required for total evacuation: 2:32
- Total Occupants Evacuated: 4
- Fire Code Violations: None
- Equipment Failure: None
- Procedural Observations: Occupants gathered too close to the building
 - o Action Step: Remind occupants to move at least 100 feet away from the building in the back parking lot