



**ARKANSAS STATE  
UNIVERSITY**

# **2025 Annual Fire Safety Report**

Published: October 1, 2025

**Arkansas State University  
2105 Aggie Road  
Jonesboro, AR 72401**

—  
**Prepared by: Wyatt A. Reed**

**Emergency Operations and Occupational Safety Specialist  
Office of Emergency Management  
Arkansas State University**  
**Contact: [WReed@AStrate.edu](mailto:WReed@AStrate.edu), ext. 3352**

## Table of Contents

Table of Contents.....	1
Introduction .....	3
Purpose .....	3
Disclosure of Information .....	3
A-State Fire Safety Program.....	4
Objectives.....	4
Awareness.....	4
Mitigation.....	4
Training and Exercises.....	4
Policies and Procedures .....	5
Purpose .....	5
Adoption of Code .....	5
Electrical Equipment .....	5
Decorations.....	5
Prohibited Items .....	6
Fire Protection Systems .....	6
Fire Inspections .....	7
Smoke-Free Campus .....	7
Greek Life Fire Policies .....	7
Exercises.....	10
2024 Exercises.....	10
Exercise Expectations.....	10
Permits .....	10
Emergency Evacuation.....	11
Purpose .....	11
Evacuation Procedures .....	11
Access and Functional Needs.....	11
University Response.....	11

Calendar Year 2024 Fire Statistics Summary .....	12
Calendar Year 2023 Fire Statistics Summary .....	17
Calendar Year 2022 Fire Statistics Summary .....	22
Calendar Year 2021 Fire Statistics Summary .....	27
Overview of Fire Protection Systems.....	32
Objectives.....	32
Non-Supervised Fire Alarm System .....	32
Supervised Fire Alarm System .....	32
Full Wet Sprinkler System .....	32
Partial Wet Sprinkler System .....	32
Partial Dry Sprinkler System .....	32
Smoke Detectors.....	32
Heat Detectors.....	32
Fire Extinguishers .....	32
Evacuation Plans/Placards .....	32
Kitchen Hood System .....	32
2024 Fire Protection Systems and Drills .....	33
Future Improvements .....	38
Improvement Plan .....	38
Conclusion of Report.....	38

## Introduction

### Purpose

Arkansas State University is publishing this Annual Fire Safety Report in compliance with Federal law and in keeping with the commitment of A-State to operating a safe campus.

The Higher Education Opportunity Act of 2008 requires all institutions of higher education to develop an annual fire safety report of certain fire statistics for on-campus residential housing facilities. This report will contain the following, in compliance with 34 CFR 668.49(b):

- Fire statistics as defined by 34 CFR 668.49(c),
- A description of each on-campus student housing facility's fire safety system,
- The number of fire drills held during the previous calendar year,
- A-State's policies or rules on portable electrical appliances, smoking, and open flames in a student housing facility,
- A-State's procedures for student housing evacuation in the case of a fire,
- The policies regarding fire safety education and training programs provided to students and employees,
- A list of each person or organization to which students and employees should report that a fire occurred for documentation purposes, and,
- Plans for future improvements in fire safety, as determined necessary by A-State.

### Disclosure of Information

This public disclosure is intended to inform current and prospective students and employees of the fire safety programs and policies in place at Arkansas State. It may also be used as a gauge of A-State's state of readiness to detect and respond to fire-related emergencies.

This report is a public record and will be readily available for viewing on the university website. Additionally, copies of this report may be obtained in person or via email by request to the Office of Emergency Management during normal university business hours. Our office is located on the first floor of the Administration Building, Room 117. We may also be reached by calling (870) 972-2862. For email requests, contact **Wyatt Reed** at [WReed@AState.edu](mailto:WReed@AState.edu).

# A-State Fire Safety Program

## Objectives

A-State works diligently to maintain an effective fire safety program. The program exists to:

1. Create awareness of potentially hazardous conditions,
2. Mitigate hazards identified by both internal and external partners,
3. Ensure adequate training and exercises are conducted to increase readiness,
4. Keep campus members safe.

### Awareness

Arkansas State promotes awareness of potentially hazardous conditions using public outreach tools and training. The university maintains a detailed list of items and devices that are likely to present a fire hazard to campus members and works to distribute this amongst residents using the University Housing webpage. Additionally, training is available in the Taleo Employee Learn Center regarding fire safety, including identifying hazardous conditions. The Office of Emergency Management works to teach campus members best practices regarding hazardous conditions and maintains reporting methods. If campus members identify conditions they believe present a fire hazard, they can report them at [RedWolv.es/SafetyConcerns](https://RedWolv.es/SafetyConcerns).

### Mitigation

Arkansas State prides itself on operating a campus where residents can feel safe. The Office of Emergency Management works closely with life safety partners such as the Jonesboro Fire Department, the State of Arkansas Fire Marshal's Office, and external vendors that assist in keeping our community mitigated against potential hazards. These mitigation activities include:

- ✓ Annual inspections to ensure code compliance
- ✓ Compliance with Arkansas law
- ✓ Compliance with local ordinances
- ✓ Encouraging best practices to be used by campus members
- ✓ Implementation of fire protection systems
  - Alarm systems, extinguishers, prevention systems, etc.

### Training and Exercises

Arkansas State strives to provide training and stimulating exercises that encourage students to be active participants in all fire safety program objectives. Training is available by request to our office in addition to the information distributed to each resident at the beginning of the academic year. Furthermore, training is conducted with residence hall staff as a grassroots effort to promote a culture of safety and knowledge amongst not only our university's staff but our residents as well. Drills are conducted each main semester to evaluate the effectiveness of plans, training, and university readiness.

## Policies and Procedures

### Purpose

The Office of Emergency Management compiles these policies and procedures in conjunction with life safety partners to ensure our campus follows best practices and applicable laws. These policies and procedures are not an exhaustive list, but should generally provide good insight into standards set forth by the university regarding expectations.

### Adoption of Code

Arkansas State University is legally bound to follow the Arkansas Fire Prevention Code. The most recent revision was passed in 2021 and came into effect at the beginning of 2023.

Arkansas State University follows the 2021 Arkansas Fire Prevention Code in accordance with AR Admin Rules 015.01.22-005 and AR Code § 12-13-105 (2020).

### Electrical Equipment

Electrical equipment, including extension cords, power taps, appliances, etc., should be in good working order. Where possible, appliances such as these must be listed by Underwriters Laboratory (UL). Please note the following policies:

- ✗ No appliances may be used in residence halls that do not meet the parameters outlined in the University Housing Policies/Procedures and/or the Student Handbook
- ✗ No extension cord may be plugged into another, nor run through a ceiling/door.
- ✗ No heavy appliances (refrigerators, washers, etc.) may be plugged into a power tap or extension cord
- ✗ No power tap may be plugged into another per Policy 05-41(2.5)
- ✗ No space heaters or similar devices may be used per Policy 04-25

University safety officials reserve the right to deem conditions hazardous and bring a cause of mitigation upon those conditions as deemed necessary.

### Decorations

While decorations in residence halls are encouraged, they must be displayed in a manner consistent with the safety culture and policy of the university. Note the following:

- Decorations may not be displayed in fire-rated spaces, such as stairwells
- Decorations may not obstruct a means of egress
- Decorations may not obstruct fire protection systems or emergency equipment
  - This includes extinguishers, exit signs, fire panels, etc.
- Decorations should be flame-resistant and/or non-combustible
- No tree, plant, or greenery, either live or cut, may be used by residents.
  - Small plants are acceptable, at the discretion of campus safety personnel

## Prohibited Items

The following are items that are prohibited in residential facilities of Arkansas State University:

- ✗ Automobile batteries
- ✗ Cooking appliances that have a heating element, whether closed or open.
  - Ex. Griddles, pressure cookers, George Foreman grills, hot plates, etc.
  - This does not apply to Collegiate Park, Pack Place, Red Wolf Den, The Circle, or The Village Apartments.
- ✗ Electric hoverboards, scooters, bikes, and similar devices
- ✗ Flammable and/or corrosive liquids
  - Exceptions are permitted for small amounts of cleaning supplies, provided they are properly stored and protected at the discretion of the EHS Director
- ✗ Fuels/accelerants
- ✗ Grills and smokers
  - Exceptions are permitted for Fraternity Houses, provided the grills are stored, maintained, and used safely.
- ✗ Halogen Lamps
- ✗ Internal combustion engines
- ✗ Open flames, to include matches, lighters, candles, fires, etc.
- ✓ You may have refrigerators and microwaves, provided they comply with University Housing rules, regulations, and policies.

## Fire Protection Systems

A-State prides itself on operating high-quality fire protection systems in most of its residential facilities. A great amount of time and money is spent upgrading and maintaining these systems. As such, residents need to understand these systems, how they work, when to utilize them, and most importantly, not to tamper with them. Malfunctioning equipment must be reported to Facilities Management using the University Housing Work Order Request Form.

Tampering with fire protection systems is against university policy and, at times, can violate Arkansas law. Residents found tampering with equipment will be referred to the Office of Student Conduct for appropriate disciplinary action, which could include fines or service charges. Tampering with equipment could include, but is not limited to, the following:

- ✗ Creating a false alarm (especially with malicious intent),
- ✗ Disconnecting a smoke/heat detector,
- ✗ Obstruction of protection equipment, such as fire doors, extinguishers, sprinklers, etc.,
- ✗ Propping of doors designed to be closed in a fire-rated space,
- ✗ Removal/relocation of fire protection equipment without prior authorization,
- ✗ Silencing/manipulating a fire panel without authorization.

## Fire Inspections

University Housing partners schedule fire inspections (generally bi-monthly) to ensure that safety measures are being implemented and that hazardous conditions are not present as outlined in the policies and procedures section of this document. In addition to these inspections, the Office of Emergency Management works with internal and external partners to inspect fire safety equipment and to evaluate compliance with code standards. Depending upon the hazard identified, steps will be taken to mitigate the hazard. Disciplinary action, including referrals to the Office of Student Conduct, may be taken if the case warrants.

The Office of Emergency Management works with Greek Life partners to ensure adequate inspection of fraternity houses is performed, whether on or off campus.

Additional concerns may be addressed to the Office of Emergency Management by emailing [EmergencyOps@ASState.edu](mailto:EmergencyOps@ASState.edu), calling (870) 972-2862, or submitting a report at [RedWolv.es/SafetyConcerns](http://RedWolv.es/SafetyConcerns).

## Smoke-Free Campus

Arkansas State University does not allow the smoking of tobacco or similar products pursuant to AR Code § 6-60-804 (2020), more generally referred to as The Clean Air on Campus Act of 2009. This aligns with Arkansas State University Policy #03-05. This provision applies to any facility in which the land and/or building is owned by the university.

## Greek Life Fire Policies

### Compliance & Inspections

Any chapter houses and suites must comply with all applicable fire codes, health regulations, and laws or regulations. Arkansas State University will assist in coordinating fire inspections each semester. These inspections are performed in partnership with the Office of Greek Life, Office of Emergency Management, Jonesboro Fire Department, and any necessary law enforcement agencies. Any chapters not on university-owned property may arrange for an alternate source to conduct semester fire inspections; however, proper documentation of said inspection must be submitted to the Office of Greek Life no later than two business days following the inspection. A copy of this report must also be submitted to **Wyatt Reed** ([WReed@ASState.edu](mailto:WReed@ASState.edu)) within the same time frame for documentation purposes.

### Emergency Numbers

Any chapters with a form of housing must have emergency numbers for fire, police, and ambulance posted by common phones and in other locations, and should have evacuation routes posted on the back of the door of each sleeping room. The Office of Emergency Management may have resources to assist with these requirements.

### **Firearms & Explosives Prohibited**

The possession and/or use of firearms or explosive devices (including fireworks) of any kind within the confines and premises of any chapter house or suite are expressly forbidden.

### **Fire Reporting Required**

All fires shall be reported to the Arkansas State University Office of Emergency Management as soon as possible. A Fire Incident Reporting Form should be completed. This form is available on the Office of Emergency Management's webpage. Reportable fires are defined as "any instance of open flame or other burning in a place not intended to contain the burning or in an uncontrolled manner." NOTE: An open flame or evidence of an open flame MUST be present to qualify. A notification should also be sent to **Wyatt Reed** ([WReed@ASState.edu](mailto:WReed@ASState.edu)) and **Ronnie Gilley** ([RGilley@ASState.edu](mailto:RGilley@ASState.edu)) within 24 hours of the incident. Failure to comply could result in sanctions. A report form is available at [RedWolv.es/FireReport](http://RedWolv.es/FireReport).

### **Permitting Required**

The Arkansas State University Office of Emergency Management requires permits for some events within Greek Life activities that involve fire. The purpose of the permitting process is to ensure emergency response personnel are aware of activities that may contain hazardous components. All permits are to be sent to the Office of Emergency Management using a CampusOptics form readily available on both the Emergency Management webpage and the Greek Life webpage. They are also linked in the respective permits below.

### **Fire Permitting Requirements**

Fires within grills or small flames such as candles are allowed without permit approval (fraternity housing only). All other fires, including bonfires, pit fires, barrel fires, etc., require a permit to ensure compliance with university policy and applicable laws and/or ordinances.

**However, if a burn ban exists, the ability of any fire (contained or not) to be burned is at the discretion of the Arkansas State University Office of Emergency Management.** They may be contacted at (870) 972-2862 for clearance. Permit requests are available at [RedWolv.es/FirePermit](http://RedWolv.es/FirePermit).

### **Sorority Housing Note**

Because sorority housing at Arkansas State is operated through University Housing, residents within one of the five sorority house options on campus must abide by the University Housing rules. Some allowances (such as grills and candles) may not be permitted in sorority housing. Please consult the latest edition of the Student Handbook for the most accurate policies on University Housing expectations.

### Controlled Burn Permit

Any fire other than that contained in a grill or that is relatively small (such as a candle) requires completion and issuance of a Controlled Burn Permit, located on both the Office of Emergency Management webpage and the Greek Life webpage. This permit request should be submitted no later than five (5) business days before the event. Non-contained fires must meet the following conditions as prescribed by Arkansas State University and City of Jonesboro Ordinance ORD-04.293:

- ✓ Materials to be burned must consist of wood only
- ✓ Materials may be placed in a pile no larger than three feet in diameter and two feet in height
- ✓ Burning must be at least 25 feet from the nearest structure
- ✓ Burning must be at least 25 feet from the nearest property line
- ✓ Fire must be attended to at all times
- ✓ Fire attendant(s) must have a charged hose and/or sufficient water available to completely extinguish the fire in the event that it spreads
- ✓ Open burning may not occur when a Wind Advisory is issued for Jonesboro or Craighead County

Controlled Burn Permit requests are available at [RedWolv.es/FirePermit](https://RedWolv.es/FirePermit).

### Fire Safety Plan

Beginning with the Fall 2024 semester, fraternity organizations with housing on or near campus must complete a fire safety plan. This plan shall include the following (at a minimum):

- ✓ Emergency Contact Information
- ✓ Fire Hazard Identification and Prevention Plan
- ✓ Mitigation Plan
- ✓ Response Plan
- ✓ Statement of Cooperation and Continuity

These shall be submitted to Wyatt Reed ([WReed@AState.edu](mailto:WReed@AState.edu)), Ronnie Gilley ([RGilley@AState.edu](mailto:RGilley@AState.edu)), and Abby Dorton ([ADorton@AState.edu](mailto:ADorton@AState.edu)) by October 1<sup>st</sup> of every year, and any updates to the plan must be made known to these contacts within 5 business days.

Additional information and support for the creation and maintenance of these plans is available by reaching out to the Office of Emergency Management at (870) 972-2862.

## Exercises

### 2024 Exercises

Arkansas State hosts exercises to promote collaboration with campus partners and to increase readiness amongst our campus members. In 2024, exercises were held at a drill and tabletop level. The 2024 Spring Fire Drill After-Action Report (AAR) is available on the Office of Emergency Management's webpage or at [RedWolv.es/S24FireAAR](https://RedWolv.es/S24FireAAR). The 2024 Fall Fire Drill After-Action Report (AAR) is available on the Office of Emergency Management's webpage or at [RedWolv.es/F24FireAAR](https://RedWolv.es/F24FireAAR). A drill was held in the spring and fall for sorority houses, Pack Place, the LLCs, Northpark Quads, and Residence Halls. Emergency Management evaluated the time of evacuation, effectiveness, adherence to established procedures, and working order of fire notification systems. Additionally, campus leadership and emergency management personnel conducted a tabletop exercise in July 2024 for a fire incident at the Lab Science Complex. This AAR is available at [RedWolv.es/24LabFireAAR](https://RedWolv.es/24LabFireAAR).

### Exercise Expectations

Exercises are coordinated to identify strengths and weaknesses within the emergency response procedures. A-State maintains an Emergency Action Plan (EAP), which outlines the emergency responses residents should take in response to a fire. This plan, along with evacuation policies, is used as a guide for response expectations. You may view the EAP at [RedWolv.es/EAP24](https://RedWolv.es/EAP24). Additionally, these documents are readily available on the Office of Emergency Management's webpage and are distributed frequently throughout the year. Those who fail to adequately participate in exercises or refuse to meet expectations are referred to the Office of Student Conduct. For 2024, 6 residents were reported for failing to properly participate in exercises in the Spring 2024 term drills, and 0 residents were reported in the Fall 2024 term.

## Permits

The Office of Emergency Management requires permits for any event within University Housing or on residential facility property that includes open flames. Specifically, events like bonfires, fire-dancing, etc., require a permit to be issued by the Office of Emergency Management. This ensures appropriate hazards and life safety considerations have been evaluated.

Failure to apply for proper permitting can lead to event cancellation, suspension periods, and other sanctions as deemed appropriate. In general, any open flame that exists outside of the above Greek Life policies requires a permit through the Office of Emergency Management. Few exceptions are made.

Refer to the Student Handbook and the Greek Life section of this report for permit requirements.

# Emergency Evacuation

## Purpose

In the event of a fire, an evacuation of a building is necessary. Fires can spread quickly, and delaying evacuating subjects residents, staff, and first responders to unnecessary risk. Failure to comply with an evacuation order (including an audible or visual fire alarm) will result in a referral of the resident to the Office of Student Conduct.

## Evacuation Procedures

In general, residents ordered to evacuate should seek their nearest emergency exit. Ideally, this would be identified before the emergency, but most emergency exits are marked with emergency exit signs. Usage of elevators is not permitted, as they are reserved for first responders. If possible, lock your door behind you. Evacuate to the identified assembly area. If it is inaccessible or unidentified, find an open spot that will be safe and out of the way of first responders. If any authority having jurisdiction (AHJ) orders you to respond differently, you are obligated to comply with their instructions. If a larger-scale evacuation becomes necessary, instructions will be transmitted in accordance with A-State's Emergency Notification Policy.

Arkansas State University maintains an Emergency Action Plan with guidance on proper procedures for fires, evacuations, and other emergencies. This plan is available at [RedWolv.es/EAP24](http://RedWolv.es/EAP24). Evacuation instructions can be found at [RedWolv.es/HousingSafety](http://RedWolv.es/HousingSafety).

## Access and Functional Needs

Individuals with access and functional needs are encouraged to seek shelter in fire-rated spaces if unable to evacuate the building. For example, fire-rated stairwells are designed by code to prevent fire from entering for at least two hours to allow individuals a means of egress during a fire incident. For example, if you use a wheelchair, seek shelter in a stairwell landing. This fire-rated space is designed to provide safety long enough for first responders to assist you out of the building. It is also a good idea to call A-State's University Police Dispatch Center at (870) 972-2093 to ensure that first responders are aware of your location.

For more information on fire-rated spaces, you may contact the Office of Emergency Management at (870) 972-2862.

## University Response

Campus members must immediately report Clery-defined fires to **Wyatt Reed** at [WReed@AState.edu](mailto:WReed@AState.edu) for entry into the fire log. A report may also be made at [RedWolv.es/FireReport](http://RedWolv.es/FireReport).

## Calendar Year 2024 Fire Statistics Summary

### 2024 Arkansas State University Fire Statistics (01.01.2024 to 12.31.2024)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Residence Halls</b>						
Arkansas Hall	2509 Aggie Road	0	N/A	0	0	N/A
Kays Hall	125 Dean Street	0	N/A	0	0	N/A
University Hall	113 Dean Street	0	N/A	0	0	N/A
<b>Northpark Quads</b>						
Northpark Quad #1	1115 University Loop East #1	0	N/A	0	0	N/A
Northpark Quad #2	1115 University Loop East #2	0	N/A	0	0	N/A
Northpark Quad #3	1115 University Loop East #3	1	Unintentional: Lithium battery explosion.	0	0	\$0-99
Northpark Quad #4	1115 University Loop East #4	1	Unintentional: Trash can fire.	0	0	\$100-999
Northpark Quad #5	1115 University Loop East #5	0	N/A	0	0	N/A
<b>Living Learning Communities</b>						
LLC #1	2515 Danner Avenue #1	0	N/A	0	0	N/A
LLC #2	2515 Danner Avenue #2	0	N/A	0	0	N/A
LLC #3	2515 Danner Avenue #3	0	N/A	0	0	N/A
LLC #4	2515 Danner Avenue #4	0	N/A	0	0	N/A
LLC #5	2515 Danner Avenue #5	0	N/A	0	0	N/A
LLC #6	2515 Danner Avenue #6	0	N/A	0	0	N/A

Table 1 of 5

# 2024 Arkansas State University Fire Statistics

## (01.01.2024 to 12.31.2024)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Sorority Houses</b>						
Zeta Tau Alpha	2410 Aggie Road	0	N/A	0	0	N/A
Alpha Gamma Delta	2502 Aggie Road	0	N/A	0	0	N/A
Alpha Omicron Pi	2504 Aggie Road	0	N/A	0	0	N/A
Chi Omega	2508 Aggie Road	0	N/A	0	0	N/A
Delta Zeta	2510 Aggie Road	0	N/A	0	0	N/A
<b>Fraternity Houses</b>						
Pi Kappa Alpha	1002 University Loop East	0	N/A	0	0	N/A
Kappa Alpha	1006 University Loop East	0	N/A	0	0	N/A
Phi Delta Theta	1007 University Loop East	0	N/A	0	0	N/A
Lambda Chi Alpha	910 University Loop East	0	N/A	0	0	N/A
Sigma Chi	904 University Loop East	0	N/A	0	0	N/A
<b>Red Wolf Den Apartments</b>						
Red Wolf Den #1	1203 University Loop East #1	0	N/A	0	0	N/A
Red Wolf Den #2	1203 University Loop East #2	0	N/A	0	0	N/A
Red Wolf Den #3	1203 University Loop East #3	0	N/A	0	0	N/A

Table 2 of 5

## 2024 Arkansas State University Fire Statistics

(01.01.2024 to 12.31.2024)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Pack Place Apartments</b>						
Pack Place #1	801 University Loop East #1	0	N/A	0	0	N/A
Pack Place #2	801 University Loop East #2	1	Unintentional: Electrical arcing fire.	0	0	\$0-99
<b>The Circle Apartments</b>						
Richmond Hall	1809 Aggie Road #1	0	N/A	0	0	N/A
Smith Hall	1809 Aggie Road #2	0	N/A	0	0	N/A
Strickland Hall	1809 Aggie Road #3	0	N/A	0	0	N/A
Gaines Hall	1809 Aggie Road #4	0	N/A	0	0	N/A
<b>Collegiate Park Apartments</b>						
Collegiate Park #1	120 Dean Street #1	0	N/A	0	0	N/A
Collegiate Park #2	121 North Caraway #2	1	Unintentional: Vent motor caught on fire.	0	0	\$100-999
Collegiate Park #3	121 North Caraway #3	0	N/A	0	0	N/A
Collegiate Park #4	121 North Caraway #4	0	N/A	0	0	N/A
Collegiate Park #5	121 North Caraway #5	0	N/A	0	0	N/A
Collegiate Park #6	120 Dean Street #6	0	N/A	0	0	N/A

Table 3 of 5

## 2024 Arkansas State University Fire Statistics

(01.01.2024 to 12.31.2024)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
The Village Apartments						
Alpine	2801 Quapaw Street	0	N/A	0	0	N/A
Aspen	2624 Pawnee Street	0	N/A	0	0	N/A
Balsa	2618 Pawnee Street	0	N/A	0	0	N/A
Birch	2807 Quapaw Street	0	N/A	0	0	N/A
Cedar	2813 Pawnee Street	0	N/A	0	0	N/A
Cypress	2612 Pawnee Street	0	N/A	0	0	N/A
Dogwood	2606 Pawnee Street	0	N/A	0	0	N/A
Douglas Fir	2819 Quapaw Street	0	N/A	0	0	N/A
Elm	2605 Cherokee Street	0	N/A	0	0	N/A
Franklin	2604 Cherokee Street	0	N/A	0	0	N/A
Ginkgo	2611 Cherokee Street	0	N/A	0	0	N/A
Hickory	2610 Cherokee Street	0	N/A	0	0	N/A
Ironwood	2617 Cherokee Street	0	N/A	0	0	N/A
Juniper	2616 Cherokee Street	0	N/A	0	0	N/A

Table 4 of 5

## 2024 Arkansas State University Fire Statistics

(01.01.2024 to 12.31.2024)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
The Village Apartments (cont.)						
Katsura	2623 Cherokee Street	0	N/A	0	0	N/A
Linden	2622 Cherokee Street	0	N/A	0	0	N/A
Magnolia	2629 Cherokee Street	0	N/A	0	0	N/A
Ninebark	2628 Cherokee Street	0	N/A	0	0	N/A
Oak	2825 Quapaw Street	0	N/A	0	0	N/A
Pine	2730 Iroquois Street	0	N/A	0	0	N/A
Quince	2723 Iroquois Street	0	N/A	0	0	N/A
Raintree	2724 Iroquois Street	0	N/A	0	0	N/A
Spruce	2717 Iroquois Street	0	N/A	0	0	N/A
Tinne	2718 Iroquois Street	0	N/A	0	0	N/A
Umbrella	2712 Iroquois Street	1	Unintentional: Grese fire.	0	0	\$100-999
Virginia	2711 Iroquois Street	0	N/A	0	0	N/A
Willow	2706 Iroquois Street	0	N/A	0	0	N/A
Yellowwood	2705 Iroquois Street	0	N/A	0	0	N/A
Zelkova	2700 Iroquois Street	0	N/A	0	0	N/A

Table 5 of 5

## Calendar Year 2023 Fire Statistics Summary

### 2023 Arkansas State University Fire Statistics (01.01.2023 to 12.31.2023)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Residence Halls</b>						
Arkansas Hall	2509 Aggie Road	0	N/A	0	0	N/A
Kays Hall	125 Dean Street	0	N/A	0	0	N/A
University Hall	113 Dean Street	0	N/A	0	0	N/A
<b>Northpark Quads</b>						
Northpark Quad #1	1115 University Loop East #1	0	N/A	0	0	N/A
Northpark Quad #2	1115 University Loop East #2	0	N/A	0	0	N/A
Northpark Quad #3	1115 University Loop East #3	0	N/A	0	0	N/A
Northpark Quad #4	1115 University Loop East #4	0	N/A	0	0	N/A
Northpark Quad #5	1115 University Loop East #5	1	Unintentional: Small fire in trash can	0	0	\$0-99
<b>Living Learning Communities</b>						
LLC #1	2515 Danner Avenue #1	0	N/A	0	0	N/A
LLC #2	2515 Danner Avenue #2	0	N/A	0	0	N/A
LLC #3	2515 Danner Avenue #3	0	N/A	0	0	N/A
LLC #4	2515 Danner Avenue #4	0	N/A	0	0	N/A
LLC #5	2515 Danner Avenue #5	0	N/A	0	0	N/A
LLC #6	2515 Danner Avenue #6	0	N/A	0	0	N/A

Table 1 of 5

## 2023 Arkansas State University Fire Statistics (01.01.2023 to 12.31.2023)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
Sorority Houses						
Zeta Tau Alpha	2410 Aggie Road	0	N/A	0	0	N/A
Alpha Gamma Delta	2502 Aggie Road	0	N/A	0	0	N/A
Alpha Omicron Pi	2504 Aggie Road	0	N/A	0	0	N/A
Chi Omega	2508 Aggie Road	0	N/A	0	0	N/A
Delta Zeta	2510 Aggie Road	0	N/A	0	0	N/A
Fraternity Houses						
Pi Kappa Alpha	1002 University Loop East	0	N/A	0	0	N/A
Kappa Alpha	1006 University Loop East	0	N/A	0	0	N/A
Phi Delta Theta	1007 University Loop East	0	N/A	0	0	N/A
Lambda Chi Alpha	910 University Loop East	0	N/A	0	0	N/A
Sigma Chi	904 University Loop East	0	N/A	0	0	N/A
Red Wolf Den Apartments						
Red Wolf Den #1	1203 University Loop East #1	0	N/A	0	0	N/A
Red Wolf Den #2	1203 University Loop East #2	0	N/A	0	0	N/A
Red Wolf Den #3	1203 University Loop East #3	0	N/A	0	0	N/A

Table 2 of 5

## 2023 Arkansas State University Fire Statistics

### (01.01.2023 to 12.31.2023)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Pack Place Apartments</b>						
Pack Place #1	801 University Loop East #1	0	N/A	0	0	N/A
Pack Place #2	801 University Loop East #2	0	N/A	0	0	N/A
<b>The Circle Apartments</b>						
Richmond Hall	1809 Aggie Road #1	0	N/A	0	0	N/A
Smith Hall	1809 Aggie Road #2	0	N/A	0	0	N/A
Strickland Hall	1809 Aggie Road #3	0	N/A	0	0	N/A
Gaines Hall	1809 Aggie Road #4	1	Unintentional: Incense burning in trash can.	0	0	\$1,000-9,999
<b>Collegiate Park Apartments</b>						
Collegiate Park #1	120 Dean Street #1	0	N/A	0	0	N/A
Collegiate Park #2	121 North Caraway #2	0	N/A	0	0	N/A
Collegiate Park #3	121 North Caraway #3	0	N/A	0	0	N/A
Collegiate Park #4	121 North Caraway #4	0	N/A	0	0	N/A
Collegiate Park #5	121 North Caraway #5	0	N/A	0	0	N/A
Collegiate Park #6	120 Dean Street #6	0	N/A	0	0	N/A

Table 3 of 5

# 2023 Arkansas State University Fire Statistics

## (01.01.2023 to 12.31.2023)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
The Village Apartments						
Alpine	2801 Quapaw Street	0	N/A	0	0	N/A
Aspen	2624 Pawnee Street	0	N/A	0	0	N/A
Balsa	2618 Pawnee Street	0	N/A	0	0	N/A
Birch	2807 Quapaw Street	0	N/A	0	0	N/A
Cedar	2813 Pawnee Street	0	N/A	0	0	N/A
Cypress	2612 Pawnee Street	0	N/A	0	0	N/A
Dogwood	2606 Pawnee Street	0	N/A	0	0	N/A
Douglas Fir	2819 Quapaw Street	0	N/A	0	0	N/A
Elm	2605 Cherokee Street	0	N/A	0	0	N/A
Franklin	2604 Cherokee Street	0	N/A	0	0	N/A
Ginkgo	2611 Cherokee Street	0	N/A	0	0	N/A
Hickory	2610 Cherokee Street	0	N/A	0	0	N/A
Ironwood	2617 Cherokee Street	0	N/A	0	0	N/A
Juniper	2616 Cherokee Street	0	N/A	0	0	N/A

Table 4 of 5

## 2023 Arkansas State University Fire Statistics (01.01.2023 to 12.31.2023)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
The Village Apartments (cont.)						
Katsura	2623 Cherokee Street	0	N/A	0	0	N/A
Linden	2622 Cherokee Street	0	N/A	0	0	N/A
Magnolia	2629 Cherokee Street	0	N/A	0	0	N/A
Ninebark	2628 Cherokee Street	0	N/A	0	0	N/A
Oak	2825 Quapaw Street	0	N/A	0	0	N/A
Pine	2730 Iroquois Street	0	N/A	0	0	N/A
Quince	2723 Iroquois Street	0	N/A	0	0	N/A
Raintree	2724 Iroquois Street	0	N/A	0	0	N/A
Spruce	2717 Iroquois Street	0	N/A	0	0	N/A
Tinne	2718 Iroquois Street	0	N/A	0	0	N/A
Umbrella	2712 Iroquois Street	0	N/A	0	0	N/A
Virginia	2711 Iroquois Street	0	N/A	0	0	N/A
Willow	2706 Iroquois Street	0	N/A	0	0	N/A
Yellowwood	2705 Iroquois Street	0	N/A	0	0	N/A
Zelkova	2700 Iroquois Street	0	N/A	0	0	N/A

Table 5 of 5

## Calendar Year 2022 Fire Statistics Summary

### 2022 Arkansas State University Fire Statistics (01.01.2022 to 12.31.2022)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
Residence Halls						
Arkansas Hall	2509 Aggie Road	0	N/A	0	0	N/A
Kays Hall	125 Dean Street	0	N/A	0	0	N/A
University Hall	113 Dean Street	0	N/A	0	0	N/A
Northpark Quads						
Northpark Quad #1	1115 University Loop East #1	0	N/A	0	0	N/A
Northpark Quad #2	1115 University Loop East #2	0	N/A	0	0	N/A
Northpark Quad #3	1115 University Loop East #3	0	N/A	0	0	N/A
Northpark Quad #4	1115 University Loop East #4	0	N/A	0	0	N/A
Northpark Quad #5	1115 University Loop East #5	0	N/A	0	0	N/A
Living Learning Communities						
LLC #1	2515 Danner Avenue #1	0	N/A	0	0	N/A
LLC #2	2515 Danner Avenue #2	0	N/A	0	0	N/A
LLC #3	2515 Danner Avenue #3	0	N/A	0	0	N/A
LLC #4	2515 Danner Avenue #4	0	N/A	0	0	N/A
LLC #5	2515 Danner Avenue #5	0	N/A	0	0	N/A
LLC #6	2515 Danner Avenue #6	0	N/A	0	0	N/A

Table 1 of 5

## 2022 Arkansas State University Fire Statistics (01.01.2022 to 12.31.2022)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
Sorority Houses						
Zeta Tau Alpha	2410 Aggie Road	0	N/A	0	0	N/A
Alpha Gamma Delta	2502 Aggie Road	0	N/A	0	0	N/A
Alpha Omicron Pi	2504 Aggie Road	0	N/A	0	0	N/A
Chi Omega	2508 Aggie Road	0	N/A	0	0	N/A
Delta Zeta	2510 Aggie Road	0	N/A	0	0	N/A
Fraternity Houses						
Pi Kappa Alpha	1002 University Loop East	0	N/A	0	0	N/A
Kappa Alpha	1006 University Loop East	0	N/A	0	0	N/A
Phi Delta Theta	1007 University Loop East	0	N/A	0	0	N/A
Lambda Chi Alpha	910 University Loop East	0	N/A	0	0	N/A
Sigma Chi	904 University Loop East	0	N/A	0	0	N/A
Red Wolf Den Apartments						
Red Wolf Den #1	1203 University Loop East #1	0	N/A	0	0	N/A
Red Wolf Den #2	1203 University Loop East #2	0	N/A	0	0	N/A
Red Wolf Den #3	1203 University Loop East #3	0	N/A	0	0	N/A

Table 2 of 5

## 2022 Arkansas State University Fire Statistics

### (01.01.2022 to 12.31.2022)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Pack Place Apartments</b>						
Pack Place #1	801 University Loop East #1	0	N/A	0	0	N/A
Pack Place #2	801 University Loop East #2	0	N/A	0	0	N/A
<b>The Circle Apartments</b>						
Richmond Hall	1809 Aggie Road #1	0	N/A	0	0	N/A
Smith Hall	1809 Aggie Road #2	0	N/A	0	0	N/A
Strickland Hall	1809 Aggie Road #3	0	N/A	0	0	N/A
Gaines Hall	1809 Aggie Road #4	0	N/A	0	0	N/A
<b>Collegiate Park Apartments</b>						
Collegiate Park #1	120 Dean Street #1	0	N/A	0	0	N/A
Collegiate Park #2	121 North Caraway #2	0	N/A	0	0	N/A
Collegiate Park #3	121 North Caraway #3	0	N/A	0	0	N/A
Collegiate Park #4	121 North Caraway #4	0	N/A	0	0	N/A
Collegiate Park #5	121 North Caraway #5	0	N/A	0	0	N/A
Collegiate Park #6	120 Dean Street #6	0	N/A	0	0	N/A

Table 3 of 5

# 2022 Arkansas State University Fire Statistics

## (01.01.2022 to 12.31.2022)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
The Village Apartments						
Alpine	2801 Quapaw Street	0	N/A	0	0	N/A
Aspen	2624 Pawnee Street	0	N/A	0	0	N/A
Balsa	2618 Pawnee Street	0	N/A	0	0	N/A
Birch	2807 Quapaw Street	0	N/A	0	0	N/A
Cedar	2813 Pawnee Street	0	N/A	0	0	N/A
Cypress	2612 Pawnee Street	0	N/A	0	0	N/A
Dogwood	2606 Pawnee Street	0	N/A	0	0	N/A
Douglas Fir	2819 Quapaw Street	0	N/A	0	0	N/A
Elm	2605 Cherokee Street	0	N/A	0	0	N/A
Franklin	2604 Cherokee Street	0	N/A	0	0	N/A
Ginkgo	2611 Cherokee Street	0	N/A	0	0	N/A
Hickory	2610 Cherokee Street	0	N/A	0	0	N/A
Ironwood	2617 Cherokee Street	0	N/A	0	0	N/A
Juniper	2616 Cherokee Street	0	N/A	0	0	N/A

Table 4 of 5

## 2022 Arkansas State University Fire Statistics (01.01.2022 to 12.31.2022)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
The Village Apartments (cont.)						
Katsura	2623 Cherokee Street	0	N/A	0	0	N/A
Linden	2622 Cherokee Street	0	N/A	0	0	N/A
Magnolia	2629 Cherokee Street	0	N/A	0	0	N/A
Ninebark	2628 Cherokee Street	1	Unintentional: Small grease fire in the kitchen	0	0	\$0-99
Oak	2825 Quapaw Street	0	N/A	0	0	N/A
Pine	2730 Iroquois Street	0	N/A	0	0	N/A
Quince	2723 Iroquois Street	0	N/A	0	0	N/A
Raintree	2724 Iroquois Street	0	N/A	0	0	N/A
Spruce	2717 Iroquois Street	0	N/A	0	0	N/A
Tinne	2718 Iroquois Street	0	N/A	0	0	N/A
Umbrella	2712 Iroquois Street	0	N/A	0	0	N/A
Virginia	2711 Iroquois Street	0	N/A	0	0	N/A
Willow	2706 Iroquois Street	0	N/A	0	0	N/A
Yellowwood	2705 Iroquois Street	0	N/A	0	0	N/A
Zelkova	2700 Iroquois Street	0	N/A	0	0	N/A

Table 5 of 5

## Calendar Year 2021 Fire Statistics Summary

### 2021 Arkansas State University Fire Statistics (01.01.2021 to 12.31.2021)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Residence Halls</b>						
Arkansas Hall	2509 Aggie Road	1	Unintentional: Small kitchen fire.	0	0	\$0-99
Kays Hall	125 Dean Street	0	N/A	0	0	N/A
University Hall	113 Dean Street	0	N/A	0	0	N/A
<b>Northpark Quads</b>						
Northpark Quad #1	1115 University Loop East #1	0	N/A	0	0	N/A
Northpark Quad #2	1115 University Loop East #2	0	N/A	0	0	N/A
Northpark Quad #3	1115 University Loop East #3	0	N/A	0	0	N/A
Northpark Quad #4	1115 University Loop East #4	0	N/A	0	0	N/A
Northpark Quad #5	1115 University Loop East #5	0	N/A	0	0	N/A
<b>Living Learning Communities</b>						
LLC #1	2515 Danner Avenue #1	0	N/A	0	0	N/A
LLC #2	2515 Danner Avenue #2	0	N/A	0	0	N/A
LLC #3	2515 Danner Avenue #3	0	N/A	0	0	N/A
LLC #4	2515 Danner Avenue #4	0	N/A	0	0	N/A
LLC #5	2515 Danner Avenue #5	0	N/A	0	0	N/A
LLC #6	2515 Danner Avenue #6	1	Unintentional: Burnt Motor	0	0	\$100-999

Table 1 of 5

# 2021 Arkansas State University Fire Statistics

## (01.01.2021 to 12.31.2021)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Sorority Houses</b>						
Zeta Tau Alpha	2410 Aggie Road	0	N/A	0	0	N/A
Alpha Gamma Delta	2502 Aggie Road	0	N/A	0	0	N/A
Alpha Omicron Pi	2504 Aggie Road	0	N/A	0	0	N/A
Chi Omega	2508 Aggie Road	0	N/A	0	0	N/A
Delta Zeta	2510 Aggie Road	0	N/A	0	0	N/A
<b>Fraternity Houses</b>						
Pi Kappa Alpha	1002 University Loop East	0	N/A	0	0	N/A
Kappa Alpha	1006 University Loop East	0	N/A	0	0	N/A
Phi Delta Theta	1007 University Loop East	0	N/A	0	0	N/A
Lambda Chi Alpha	910 University Loop East	0	N/A	0	0	N/A
Sigma Chi	904 University Loop East	0	N/A	0	0	N/A
<b>Red Wolf Den Apartments</b>						
Red Wolf Den #1	1203 University Loop East #1	0	N/A	0	0	N/A
Red Wolf Den #2	1203 University Loop East #2	0	N/A	0	0	N/A
Red Wolf Den #3	1203 University Loop East #3	0	N/A	0	0	N/A

Table 2 of 5

# 2021 Arkansas State University Fire Statistics

## (01.01.2021 to 12.31.2021)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>Pack Place Apartments</b>						
Pack Place #1	801 University Loop East #1	0	N/A	0	0	N/A
Pack Place #2	801 University Loop East #2	0	N/A	0	0	N/A
<b>The Circle Apartments</b>						
Richmond Hall	1809 Aggie Road #1	0	N/A	0	0	N/A
Smith Hall	1809 Aggie Road #2	0	N/A	0	0	N/A
Strickland Hall	1809 Aggie Road #3	0	N/A	0	0	N/A
Gaines Hall	1809 Aggie Road #4	0	N/A	0	0	N/A
<b>Collegiate Park Apartments</b>						
Collegiate Park #1	120 Dean Street #1	0	N/A	0	0	N/A
Collegiate Park #2	121 North Caraway #2	0	N/A	0	0	N/A
Collegiate Park #3	121 North Caraway #3	0	N/A	0	0	N/A
Collegiate Park #4	121 North Caraway #4	0	N/A	0	0	N/A
Collegiate Park #5	121 North Caraway #5	0	N/A	0	0	N/A
Collegiate Park #6	120 Dean Street #6	0	N/A	0	0	N/A

Table 3 of 5

# 2021 Arkansas State University Fire Statistics

## (01.01.2021 to 12.31.2021)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
The Village Apartments						
Alpine	2801 Quapaw Street	0	N/A	0	0	N/A
Aspen	2624 Pawnee Street	0	N/A	0	0	N/A
Balsa	2618 Pawnee Street	0	N/A	0	0	N/A
Birch	2807 Quapaw Street	0	N/A	0	0	N/A
Cedar	2813 Pawnee Street	0	N/A	0	0	N/A
Cypress	2612 Pawnee Street	0	N/A	0	0	N/A
Dogwood	2606 Pawnee Street	0	N/A	0	0	N/A
Douglas Fir	2819 Quapaw Street	0	N/A	0	0	N/A
Elm	2605 Cherokee Street	0	N/A	0	0	N/A
Franklin	2604 Cherokee Street	0	N/A	0	0	N/A
Ginkgo	2611 Cherokee Street	0	N/A	0	0	N/A
Hickory	2610 Cherokee Street	0	N/A	0	0	N/A
Ironwood	2617 Cherokee Street	0	N/A	0	0	N/A
Juniper	2616 Cherokee Street	0	N/A	0	0	N/A

Table 4 of 5

# 2021 Arkansas State University Fire Statistics

## (01.01.2021 to 12.31.2021)

Building	Address	Number of Fires	Cause of Fire(s)	Injuries	Fatalities	Value of Property Damage
<b>The Village Apartments (cont.)</b>						
Katsura	2623 Cherokee Street	0	N/A	0	0	N/A
Linden	2622 Cherokee Street	0	N/A	0	0	N/A
Magnolia	2629 Cherokee Street	0	N/A	0	0	N/A
Ninebark	2628 Cherokee Street	0	N/A	0	0	N/A
Oak	2825 Quapaw Street	0	N/A	0	0	N/A
Pine	2730 Iroquois Street	0	N/A	0	0	N/A
Quince	2723 Iroquois Street	0	N/A	0	0	N/A
Raintree	2724 Iroquois Street	0	N/A	0	0	N/A
Spruce	2717 Iroquois Street	0	N/A	0	0	N/A
Tinne	2718 Iroquois Street	0	N/A	0	0	N/A
Umbrella	2712 Iroquois Street	0	N/A	0	0	N/A
Virginia	2711 Iroquois Street	0	N/A	0	0	N/A
Willow	2706 Iroquois Street	0	N/A	0	0	N/A
Yellowwood	2705 Iroquois Street	0	N/A	0	0	N/A
Zelkova	2700 Iroquois Street	0	N/A	0	0	N/A

Table 5 of 5

# Overview of Fire Protection Systems

## Objectives

Each of Arkansas State University's residential facilities contains fire protection systems. While an overview is available, the following are definitions of the systems found in the overview.

### Non-Supervised Fire Alarm System

A non-supervised alarm system will create an audible and visual alarm, but the panel is not connected to a monitoring service or a safety answering point.

### Supervised Fire Alarm System

In addition to making an audible and visual alarm to occupants, a notification will be sent to the connected monitoring service or public safety answering point, assuming the unit is in working condition.

### Full Wet Sprinkler System

A sprinkler system that contains water throughout the entirety of a building.

### Partial Wet Sprinkler System

A sprinkler system that contains water throughout portions of a building.

### Partial Dry Sprinkler System

A sprinkler system that contains water behind a pocket of air throughout portions of a building.

### Smoke Detectors

Devices monitoring for conditions and parameters that indicate smoke.

### Heat Detectors

Devices monitoring for conditions that indicate an abnormal amount of heat.

### Fire Extinguishers

Portable tanks containing chemical agents designed to be sprayed on a fire to extinguish it.

### Evacuation Plans/Placards

Documents established that communicate an emergency evacuation plan, including exits, routes, procedures, and assembly areas. Placards may also be in common spaces of the building.

### Kitchen Hood System

A hood system designed to release a chemical agent to extinguish an uncontrolled flame.

## 2024 Fire Protection Systems and Drills

### 2024 Arkansas State University Fire Systems/Drills (01.01.2024 to 12.31.2024)

Building	Address	Description of Fire Protection Systems	Number of Drills
<b>Residence Halls</b>			
Arkansas Hall	2509 Aggie Road	Supervised Fire Alarm System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
Kays Hall	125 Dean Street	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke/Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
University Hall	113 Dean Street	Supervised Fire Alarm System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
<b>Northpark Quads</b>			
Northpark Quad #1	1115 University Loop East #1	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
Northpark Quad #2	1115 University Loop East #2		2
Northpark Quad #3	1115 University Loop East #3		2
Northpark Quad #4	1115 University Loop East #4		2
Northpark Quad #5	1115 University Loop East #5		2
<b>Living Learning Communities</b>			
LLC #1	2515 Danner Avenue #1	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
LLC #2	2515 Danner Avenue #2		2
LLC #3	2515 Danner Avenue #3		2
LLC #4	2515 Danner Avenue #4	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Kitchen Hood System, Evacuation Plans/Placards	2
LLC #5	2515 Danner Avenue #5		2
LLC #6	2515 Danner Avenue #6		2

Table 1 of 5

# 2024 Arkansas State University Fire Systems/Drills

## (01.01.2024 to 12.31.2024)

Building	Address	Description of Fire Protection Systems	Number of Drills
<b>Sorority Houses</b>			
Zeta Tau Alpha	2410 Aggie Road		2
Alpha Gamma Delta	2502 Aggie Road		2
Alpha Omicron Pi	2504 Aggie Road	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Kitchen Hood System, Evacuation Plans/Placards	2
Chi Omega	2508 Aggie Road		2
Delta Zeta	2510 Aggie Road		2
<b>Fraternity Houses</b>			
Pi Kappa Alpha	1002 University Loop East	Fire Extinguishers, Smoke Detectors, Evacuation Plans/Placards	N/A
Phi Delta Theta	1007 University Loop East	Fire Extinguishers, Smoke Detectors, Kitchen Hood System, Evacuation Plans/Placards	N/A
Kappa Alpha	1006 University Loop East		N/A
Lambda Chi Alpha	910 University Loop East	Supervised Fire Alarm System, Smoke Detectors, Fire Extinguishers	N/A
Sigma Chi	904 University Loop East		N/A
<b>Red Wolf Den Apartments</b>			
Red Wolf Den #1	1203 University Loop East #1	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Extinguishers	1
Red Wolf Den #2	1203 University Loop East #2		1
Red Wolf Den #3	1203 University Loop East #3	<b><i>Note: Detectors are not connected to the supervised system.</i></b>	1

Table 2 of 5

# 2024 Arkansas State University Fire Systems/Drills

## (01.01.2024 to 12.31.2024)

Building	Address	Description of Fire Protection Systems	Number of Drills
<b>Pack Place Apartments</b>			
Pack Place #1	801 University Loop East #1	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
Pack Place #2	801 University Loop East #2	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
<b>The Circle Apartments</b>			
Richmond Hall	1809 Aggie Road #1		2
Smith Hall	1809 Aggie Road #2	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
Strickland Hall	1809 Aggie Road #3	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
Gaines Hall	1809 Aggie Road #4	Supervised Fire Alarm System, Full Wet Sprinkler System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	2
<b>Collegiate Park Apartments</b>			
Collegiate Park #1	120 Dean Street #1	Smoke Detectors, Fire Extinguishers	0
Collegiate Park #2	121 North Caraway #2	Partial Wet Sprinkler System, Partial Dry Sprinkler System, Smoke Detectors, Fire Extinguishers	0
Collegiate Park #3	121 North Caraway #3	Smoke Detectors, Fire Extinguishers	0
Collegiate Park #4	121 North Caraway #4	Smoke Detectors, Fire Extinguishers	0
Collegiate Park #5	121 North Caraway #5	Partial Wet Sprinkler System, Partial Dry Sprinkler System, Smoke Detectors, Fire Extinguishers	0
Collegiate Park #6	120 Dean Street #6	Smoke Detectors, Fire Extinguishers	0
<b>Other Residential Facilities</b>			
Embassy Suites Red Wolf Convention Center	223 Red Wolf Boulevard	Supervised Fire Alarm System, Full Wet Sprinkler System, Kitchen Hood System, Smoke Detectors, Heat Detectors, Fire Extinguishers, Evacuation Plans/Placards	0

Table 3 of 5

# 2024 Arkansas State University Fire Systems/Drills

## (01.01.2024 to 12.31.2024)

Building	Address	Description of Fire Protection Systems	Number of Drills
<b>The Village Apartments</b>			
Alpine	2801 Quapaw Street	Smoke Detectors, Fire Extinguishers	0
Aspen	2624 Pawnee Street	Non-Supervised Fire Alarm System, Partial Wet Sprinkler System, Partial Dry Sprinkler System, Smoke Detectors, Fire Extinguishers	0
Balsa	2618 Pawnee Street	Smoke Detectors, Fire Extinguishers	0
Birch	2807 Quapaw Street		0
Cedar	2813 Pawnee Street		0
Cypress	2612 Pawnee Street		0
Dogwood	2606 Pawnee Street		0
Douglas Fir	2819 Quapaw Street		0
Elm	2605 Cherokee Street		0
Franklin	2604 Cherokee Street		0
Ginkgo	2611 Cherokee Street		0
Hickory	2610 Cherokee Street		0
Ironwood	2617 Cherokee Street		0
Juniper	2616 Cherokee Street		0

Table 4 of 5

# 2024 Arkansas State University Fire Systems/Drills

## (01.01.2024 to 12.31.2024)

Building	Address	Description of Fire Protection Systems	Number of Drills
The Village Apartments (cont.)			
Katsura	2623 Cherokee Street	Smoke Detectors, Fire Extinguishers	0
Linden	2622 Cherokee Street		0
Magnolia	2629 Cherokee Street	Non-Supervised Fire Alarm System, Partial Wet Sprinkler System, Partial Dry Sprinkler System, Smoke Detectors, Fire Extinguishers	0
Ninebark	2628 Cherokee Street		0
Oak	2825 Quapaw Street	Smoke Detectors, Fire Extinguishers	0
Pine	2730 Iroquois Street	Non-Supervised Fire Alarm System, Partial Wet Sprinkler System, Partial Dry Sprinkler System, Smoke Detectors, Fire Extinguishers	0
Quince	2723 Iroquois Street	Smoke Detectors, Fire Extinguishers	0
Raintree	2724 Iroquois Street		0
Spruce	2717 Iroquois Street		0
Tinne	2718 Iroquois Street		0
Umbrella	2712 Iroquois Street		0
Virginia	2711 Iroquois Street		0
Willow	2706 Iroquois Street		0
Yellowwood	2705 Iroquois Street		0
Zelkova	2700 Iroquois Street		0

Table 5 of 5

## Future Improvements

### Improvement Plan

As part of its ongoing commitment to campus safety, Arkansas State University establishes fire safety improvement plans based on the after-action report of each fire safety exercise. Details can be found at [RedWolv.es/S24FireAAR](#), [RedWolv.es/24LabFireAAR](#), and [RedWolv.es/F24FireAAR](#), respectively.

### Conclusion of Report

This report is created with the best available information and in good faith. This report is created to satisfy the requirements of Federal law as identified in 34 CFR 668.49(b). For any additional questions or concerns, please feel free to reach out to me.



### Wyatt A. Reed, CFM

Emergency Operations and Occupational Safety Specialist  
Office of Emergency Management  
Administration 117  
P.O. Box 1530 | State University, AR 72467  
p: (870) 972-3352